

	SPECIFICATION	CONDUCTOR STRUCTURE	OUTER DIAMETER OF CONDUCTOR (MM)	BELT (MM)	INSULATION THICKNESS(MM)	SHEATH THICKNESS (MM)	OUTSIDE DIAMETER (MM)	WEIGHT (kg/km)	MAXIMUM DC RESISTANCE AT 20°C (Ω /km)	TESTING VOLATAGE (KV/min)	MAXIMUM ALLOWABLE TRACTIVE FORCE (N)
YZB/YZWB	2×0.75	24/0.20	1.12	8×0.05	0.6	0.8	4.1×6.6	45.5	26	2/5	105
	2×1.0	32/0.20	1.29	5×0.05 /8×0.05	0.6	0.9	4.4×7.0	54.8	19.5	2/5	140
	2×1.5	30/0.25	1.56	8×0.05	0.8	1	5.4×8.6	80.5	13.3	2/5	210
	2×2.5	49/0.25	2	8×0.05	0.9	1.1	6.2×10.2	116	7.98	2/5	350
	2×4	56/0.30	2.56	8×0.05	1.0	1.2	7.1×11.8	166.3	4.95	2/5	560
	2×6	84/0.30	3.54	10×0.05	1.0	1.3	8.2×13.8	225.4	3.3	2/5	840
	3×0.75	24/0.20	1.12	8×0.05	0.6	0.9	4.3×6.8	60.2	26	2/5	158
	3×1.0	32/0.20	1.29	8×0.05	0.6	0.9	4.4×7.0	69.4	19.5	2/5	210
	3×1.5	30/0.25	1.56	8×0.05	0.8	1.0	5.3×8.6	102.8	13.3	2/5	315
	3×2.5	49/0.25	2	8×0.05	0.9	1.1	6.2×10.2	150.1	7.98	2/5	525
	3×4	56/0.30	2.56	8×0.05	1.0	1.2	7.1×11.8	218.8	4.95	2/5	840
	3×6	84/0.30	3.54	10×0.05	1.0	1.3	8.2×13.8	298.4	3.3	2/5	1260
	4×0.75	24/0.20	1.12	8×0.05	0.6	0.9	4.3×6.8	72.0	26	2/5	210
	4×1.0	32/0.20	1.29	8×0.05	0.6	0.9	4.4×7.0	84.0	19.5	2/5	280
	4×1.5	30/0.25	1.56	5×0.05	0.8	1.0	5.8×9.3	137.4	13.3	2/5	420
	4×2.5	49/0.25	2	5×0.05	0.9	1.1	6.6×10.7	198.0	7.98	2/5	700
	4×4	56/0.30	2.56	5×0.05	1.0	1.2	7.6×12.5	290.1	4.95	2/5	1120
	4×6	84/0.30	3.54	10×0.05	1.0	1.3	9.2×15.5	411.8	3.3	2/5	1680
	5×0.75	24/0.20	1.12	5×0.05	0.6	1.0	4.7×7.3	92.3	26	2/5	263
	5×1.0	32/0.20	1.29	5×0.05	0.6	1.0	4.9×7.7	108.5	19.5	2/5	350
	5×1.5	30/0.25	1.56	5×0.05	0.8	1.1	5.8×9.3	160.8	13.3	2/5	525
	5×2.5	49/0.25	2	5×0.05	0.9	1.3	6.8×10.9	238.3	7.98	2/5	875
	5×4	56/0.30	2.56	5×0.05	1.0	1.4	7.8×12.7	350.1	4.95	2/5	1400
	5×6	84/0.30	3.54	10×0.05	1.0	1.6	9.7×16.0	506.8	3.3	2/5	2100
	6×0.75	24/0.20	1.12	5×0.05	0.6	1.0	4.7×7.3	104.7	26	2/5	315
	6×1.0	32/0.20	1.29	5×0.05	0.6	1.1	5.1×7.9	127.2	19.5	2/5	420
	6×1.5	30/0.25	1.56	5×0.05	0.8	1.2	6.0×9.5	188.2	13.3	2/5	630
	6×2.5	49/0.25	2	5×0.05	0.9	1.4	7.0×11.1	278.7	7.98	2/5	1050
	6×4	56/0.30	2.56	5×0.05	1.0	1.5	8.1×13.0	413.0	4.95	2/5	1680
	6×6	84/0.30	3.54	10×0.05	1.0	1.7	9.9×16.2	591.9	3.3	2/5	2520
YZW	2×4	56/0.30	2.56	8×0.05	1.0	1.2	11.8	241.9	4.95	2/5	560
	2×6	84/0.30	3.54	10×0.05	1.0	1.3	13.6	397.9	3.3	2/5	840
	3×4	56/0.30	2.56	8×0.05	1.0	1.2	12.6	291.8	4.95	2/5	840
	3×6	84/0.30	3.54	10×0.05	1.0	1.3	14.4	452.6	3.3	2/5	1260
	4×4	56/0.30	2.56	8×0.05	1.0	1.2	14.0	363.9	4.95	2/5	1120
	4×6	84/0.30	3.54	10×0.05	1.0	1.3	16.0	552.5	3.3	2/5	1680
	5×4	56/0.30	2.56	8×0.05	1.0	1.4	15.5	444.8	4.95	2/5	1400
	5×6	84/0.30	3.54	10×0.05	1.0	1.6	17.8	670.6	3.3	2/5	2100
	6×0.75	24/0.20	1.12	8×0.05	0.6	1.0	9.5	142.6	26	2/5	315
	6×1.0	32/0.20	1.29	8×0.05	0.6	1.1	10.0	168.3	19.5	2/5	420
	6×1.5	30/0.25	1.56	8×0.05	0.8	1.2	12.3	251.8	13.3	2/5	630
	6×2.5	49/0.25	2	8×0.05	0.9	1.4	14.8	373.2	7.98	2/5	1050
	6×4	56/0.30	2.56	8×0.05	1.0	1.5	17.1	535.6	4.95	2/5	1680
	6×6	84/0.30	3.54	10×0.05	1.0	1.7	19.6	798.0	3.3	2/5	2520
	3×1.5+1×1.0	30/0.25 32/0.20	1.56 1.29	8×0.05 8×0.05	0.8 0.6	1.1	9	134.1	13.3	2/5	385

3×2.5+1×1.5	49/0.25 30/0.25	2.00 1.56	8×0.05 8×0.05	0.9 0.8	1.2	10.7	195.2	7.98	2/5	630
3×4+1×2.5	56/0.30 49/0.25	2.56 2.00	8×0.05 8×0.05	1.0 0.9	1.3	12.4	282.8	4.95	2/5	1015
3×6+1×4	84/0.30 56/0.30	3.54 2.56	10×0.05 8×0.05	1.0 1.0	1.4	14.4	458.5	3.3	2/5	1540